



- NOTES:
- 1). OVERLOAD RELAY SETTING: MOTOR FLC X 0.58.
  - 2). X2 TERMINAL GROUNDED AS STANDARD, REMOVE IF NOT REQUIRED.
  - 3). MI STANDS FOR MECHANICAL INTERLOCK.
  - 4). TIMING RELAY TR: RZ7-FSY2D

5	GENERAL REVISION	4-24-12	MR
REV	DESCRIPTION	DATE	APP'D
DESIGNED EAP	<p>REDUCED VOLTAGE STARTER WYE DELTA - CLOSED TRANSITION REMOTE START-STOP PUSHBUTTONS</p>	<p><b>sprecher+schuh</b> HOUSTON, TEXAS</p>	
DRAWN EAP			
APPROVED PAB			
DATE 4-9-90			
		DWG. NO.	SERIES
		CAYT WS-108-01	100