



Certificate of Compliance

Certificate: 1783916 (LR 1234)

Master Contract: 150062

Project: 70012970

Date Issued: November 13, 2014

Issued to: **Rockwell Automation, Inc.**

**Allen-Bradley
1201 South Second St
Milwaukee, WI 53204
USA**

Attention: Mr. Daniel L. Nachtigall

The products listed below are eligible to bear the CSA Mark shown



T. Munteanu

Issued by: T. Munteanu, P.Eng.

PRODUCTS

CLASS 3211 02 - INDUSTRIAL CONTROL EQUIPMENT - Kits

Cat No 193 or CEP7-EJM, -EDN, -ERR, -EPT, -EGF and -EGJ overload relay accessory modules and Cat. No. 193 or CEP7-CBCT1 and -CBCT2 current transformers for use with Submittor's solid state overload relay Cat. Nos. 193-ED1*, 193-EE*, 193S-EE*, 193R-EE*, 592-EE*, or 592S-EE*, open type, rated 24 to 240 V ac/dc, 50/60 Hz for 193 or CEP7-EJM, -ERR, -EPT, -EGF and -EGJ; 24 V dc input, B300 output for 193 or CEP7-EDN; 600 V ac, 50A 50/60 Hz for 193 or CEP7-CBCT1 and 115A 50/60 Hz -CBCT2.

Notes:

1. Open type devices are Certified as components for use only in other Certified equipment where the suitability of the combination is determined by CSA International.
2. The OLR Cat No 193-ED1* and 193-EE*, 193S-EE*, 193R-EE*, 592-EE*, and 592S-EE* are rated max 90A.
3. Cat. No. 193 and CEP7 are the same devices except for model number.

APPLICABLE REQUIREMENTS

C22.2 No. 14 - Industrial Control Equipment